NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

Kemflo Canada Inc.

Facility: Richmond Hill, Ontario, Canada

AS COMPLYING WITH NSF/ANSI/CAN 61 AND ALL APPLICABLE REQUIREMENTS.
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.

ISO/IEC 17065
Product Certification Body
#0216

Certification Program
Accredited by the
American National
Standards Institute

Certification Program
Accredited by the
Standards Council
of Canada

This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in Listing for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsf.org).

Theresa Bellish

May 26, 2020
Certificate# C0304992 - 02

Theresa Bellish
General Manager, Water Systems

NSF International

OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on December 21, 2016.

Kemflo Canada Inc.
500 Edward Avenue
Unit 2
Richmond Hill, Ontario L4C 9W6
Canada
905-832-1217

Facility: Richmond Hill, Ontario, Canada

Pipes and Related Products

Trade Designation	Size	Water Contact Temp	Water Contact Material
Fittings			
CHEMKOR	1/2" - 6"	D. HOT	CPVC
CHEMKOR	1/2" - 6"	CLD 30	PVC

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.

76220

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org

NSF International

OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 14 - Plastics Piping System Components and Related Materials

This is the Official Listing recorded on December 21, 2016.

Kemflo Canada Inc.
500 Edward Avenue
Unit 2
Richmond Hill, Ontario L4C 9W6
Canada
905-832-1217

Facility: Richmond Hill, Ontario, Canada

Potable Water - Pipe and Fittings

Product Type	Material Type	Trade Name	Product Standard
Fittings (PW) # +	*PVC*	*CHEMKOR*	*ASTM F1970*
Socket Flange			
1/2" thru 6"			
Blind Flange			
3" 4" 6"			
Vanstone Flange			
1 1/2" thru 6"			
Fittings (PW) # ++	*CPVC*	*CHEMKOR*	*ASTM F1970*
Socket Flange			
1/2" thru 6"			
Blind Flange			
3" 4" 6"			
Vanstone Flange			
1 1/2" thru 6"			

Product tested for use in 73°F with a rated pressure of 150 psi.

+ Material complies with NSF/ANSI 61 health effects requirements when tested at 73° F.

++ Material complies with NSF/ANSI 61 health effects requirements when tested at temperatures up to and including Domestic Hot (140° F).

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.

76220

789 N. Dixboro Road, Ann Arbor, Michigan 48105-9723 USA
1-800-NSF-MARK / 734-769-8010
www.nsf.org